



**FIELD CONTROLS**  
THE VENTING SOLUTIONS COMPANY

## **CK-52**

### **INSTALLATION INSTRUCTIONS ADDENDUM**

Refer to this addendum sheet and the original instruction sheet when installing the CK-52 Control Kit.

#### Wiring Diagram Change

The 16 Ga. 2 conductor wire provided with the kit has been changed from red and white to red and black. On page 3, the wire from "T4" on the Control Kit to the gas valve should be black, instead of white.