


Wiring Diagrams

for Oil Vent Damper

Oil-Fired Boiler with OVD, SWG, and CAS-3

Black, Orange, and Yellow wires from Vent Damper MUST be the same polarity or product damage will occur.



WARNING:

- DISCONNECT POWER SUPPLY BEFORE WIRING VENT DAMPER!
- DAMPER MUST BE FULLY OPEN BEFORE COMBUSTION OCCURS!

CAUTION

DO NOT EGG SHAPE PIPE ASSEMBLY OR NUISANCE CALLS MAY OCCUR.

LINE VOLTAGE BY QUALIFIED AGENCY
 LOW VOLTAGE BY QUALIFIED AGENCY
 WIRENUT

LINE VOLTAGE BY FACTORY
 LOW VOLTAGE BY FACTORY