




INSTALLATION MANUAL



This symbol on the product means the PVE-1200 is tested by Intertek to meet safety and performance standards for the U.S. and Canada.

POWER VENTER

Model: PVG-100, PVG-300, PVG-600


READ THESE INSTRUCTIONS CAREFULLY AND COMPLETELY BEFORE PROCEEDING WITH THE INSTALLATION

This device **MUST** be installed by a qualified agency in accordance with the manufacturer's installation instructions. The definition of a qualified agency is: any individual, firm, corporation or company which either in person or through a representative is engaged in, and is responsible for, the installation and operation of HVAC appliances, who is experienced in such work, familiar with all the precautions required, and has complied with all the requirements of the authority having jurisdiction. Please retain these instructions after installation.

THIS PAGE INTENTIONALLY LEFT BLANK

The Power Venter you have purchased has been designed to be simple to install, operate and maintain.
Read this manual before you install the power venter

This product should be installed according to local and national codes and standards.



Parts included in Power Venter package:



1. Power Venter
2. Draft Proving Switch
3. Terminal Blocks

Replacement Parts:



1. PVG-100 & PVG-300 Motor (46032000)
2. PVG-600 Motor (46083300)
3. PVG-100 Blower Wheel (46080100)
4. PVG-300 Blower Wheel (46033400)
5. PVG-600 Blower Wheel (46089400)
6. PVG-100 Pressure Switch (602602001)
7. PVG-300 Pressure Switch (602602002)
8. PVG-600 Pressure Switch (602602003)
9. Timer Fixed Post Purge (46282800)

TABLE OF CONTENTS

Unit Specifications.....	5
Sidewall Vent Hood.....	5
System Operation.....	5
Power Venter Sizing.....	6
Installation Safety Instructions.....	7
Installation of the Power Venter.....	8
Sidewall Vent Hood Installation.....	8
Venter Location.....	9
Connecting Venter to Flue Pipe.....	9
Optional GSK-3 Exhaust Spillage Detection Switch.....	10
General Wiring Instructions.....	10
Adjusting Thermostat Anticipator.....	11
Air Flow Adjustments.....	11
Multiple Venting Systems.....	12
PV Series Power Venter: Vertical Venting Option.....	12 - 13
General Installation Inspection.....	13
System Control Check Procedures.....	14
Maintenance.....	14
Troubleshooting.....	14

UNIT SPECIFICATIONS




Figure 1 - Unit Dimensions

Table 1

UNIT DIMENSIONS					ELECTRICAL RATINGS					
MODEL	H	W	D	I/O*	VAC	HZ	RPM	WATT	AMP	TP**
PVG-100	7.5	10.0	7.0	4/4	115	60	3000	145	2.1	YES
PVG-300	7.5	11.5	7.0	4/4	115	60	3000	145	2.1	YES
PVG-600	8.75	12.0	8.5	5/5	115	60	3000	167	1.5	YES

* Inlet and outlet diameter

** Thermally protected motor

SIDEWALL VENT HOODS

Sidewall vent hoods are available in the sizes listed below. The vent hood should be chosen that matches the outlet size of the Power Venter.

Note: Different sizes may be used as long as the reducers and specific size pipe are considered when determining equivalent length of vent pipe.

SWH-3 = 3"

SWH-4 = 4"

SWH-5 = 5"

SWH-6 = 6"

SWH-8 = 8"




Figure 2 - Typical Side Wall Vent Hood

SYSTEM OPERATION

1. The thermostat (wall thermostat or aquastat) calls for heat and energizes a relay which activates the power venter. After the venter motor has come up to speed, the pressure switch closes. This completes the circuit to the burner and allows the burner to fire.
2. For millivolt controlled water heaters, the gas pressure switch on the gas valve activates the power venter at the same time as the burner fires.
3. After the heating requirement has been satisfied, the thermostat circuit will open and deactivate the burner and power venter circuit.
4. The post purge timer continues to run the power venter for a period of time after the burner has shut off to purge remaining flue gases.

POWER VENTER SIZING



In order to choose the correct size power venter for a particular installation, the total input firing rate and total equivalent length of vent pipe to be used must be know. Refer to Table 2 to determine the maximum allowable equivalent feet pipe for each model used with the pipe diameters shown. When venting multiple appliances, add the input of each appliance to determine the total input. Always choose a power venter that is capable of handling more than the system requires. The choke plate can be adjusted to compensate for the difference.

Table 2

BTU/HR INPUT	MAXIMUM EQUIVALENT HORIZONTAL PIPE LENGTH(FEET)							
	VENTER MODEL NUMBER AND VENT PIPE DIAMETER							
	PVG-100		PVG-300			PVG-600		
	3"	4"	4"	5"	6"	5"	6"	8"
25,000	270	455	-	-	-	-	-	-
55,000	100	169	-	-	-	-	-	-
70,000	-	144	-	-	-	-	-	-
100,000	-	100	305	-	-	-	-	-
145,000	-	-	145	247	334	413	-	-
220,000	-	-	64	100	147	181	-	-
310,000	-	-	-	54	74	91	146	216
400,000	-	-	-	-	-	54	87	134
520,000	-	-	-	-	-	-	52	86
610,000	-	-	-	-	-	-	-	66

PROCEDURE FOR CALCULATING TOTAL EQUIVALENT PIPE LENGTH IN FEET

1. Calculate the total equivalent feet for each type of fitting used in the venting system from the following chart.
2. Calculate the total amount of feet for the straight lengths of vent pipe.
3. Add the equivalent feet for the fittings with the total amount of feet of straight lengths.

Table 3

VENT PIPE FITTINGS		EQUIVALENT LENGTH (FEET) OF VENT PIPE FOR VENT PIPE FITTINGS							
		VENT PIPE DIAMETER							
		3"	4"	5"	6"	7"	8"	9"	10"
TEE		19	25	31	38	44	50	56	63
90° ELBOW		5	7	9	11	12	14	16	18
45° ELBOW		3	4	4	5	6	7	8	9
REDUCER (d/D)*	¼	8	11	14	17	19	22	25	28
	½	5	7	8	10	12	13	15	17
	¾	2	3	3	4	4	5	6	6

- Reducer of increaser ratio (d/D) small diameter divided by the larger diameter. Example 4" to 8" reducer, the reducer ratio is $d/D = 4/8 = 1/2$. To estimate the equivalent foot length for the fitting, use the smaller pipe diameter for the equivalent length figure. Example 4" to 8" reducer; the reducer ratio is 1/2 and the smaller pipe diameter is 4". So, from the chart the equivalent feet would be 7 feet.

Example:

System Pipe Size = 4

Step 1 Two 4" -90° Elbows = 14 ft.

Step 2 Ten 2 Ft. Lengths of 4" Pipe = 20 ft.

Step 3 Total Equivalent Feet = 14 ft + 20 ft = 34 ft




Figure 3: Typical Pipe Fitting



INSTALLATION SAFETY INSTRUCTIONS

CAUTION: This device must be installed by a qualified installer in accordance with the manufacturer's installation instructions. Appliances should have a minimum of 75% combustion efficiency or have a maximum measured flue gas temperature of 550°F at the inlet of the venter.

1. The power venting system must be installed by a qualified installer. "Qualified Installer" shall mean an individual who has been properly trained or a licensed installer. The installer must write or imprint his/her name, phone number and date of installation on the installation tag. The tag should be attached to the power venter unit. Recording burner and venting system initial operational information is recommended as a guide for service or burner tune-up. Enter this in the space provided in this manual.
2. Safety inspection of a venting system should be performed before and after installing the power venting system on an existing or new appliance. Procedures to follow are those recommended by the National Fuel Gas Code, ANSI Z223.1 or refer to the "General Installation Inspection" section of this manual.
3. Plan the vent system layout before installation to avoid the possibility of accidental contact with concealed wiring of plumbing inside walls.
4. Single wall vent pipe may be used to join an appliance to the venting system, but if proper clearances cannot be maintained from combustible materials, Class B Vent Pipe should be used for gas appliances. Refer to national or local codes for guidelines.
5. Disconnect power supply before making wiring connections to prevent electrical shock and equipment damage.
6. This equipment is designed to overcome minor negative pressure conditions. To ensure extreme negative pressure does not exist, follow the "General Installation Inspection" section of this manual.
7. Heating appliances equipped with draft hoods, such as boilers or furnaces, LP and natural gas appliances SHOULD have a secondary spillage switch installed. On appliances without draft hoods, it is recommended that the secondary safety switch GSK-3 be installed into the system. Gas-Fired 30 millivolt power systems MUST be equipped with a spillage switch.




Diagram A: PVE Sidewall Vent Termination Locations

8. Air flow adjustment **MUST** be made to ensure appliance efficiency. This should be done at the appliance exhaust outlet with a velocity meter, draft gauge or by the "match test procedure". The match test is in accordance with National Fuel Gas Code ANSI Z223.1, Section 8.6.
9. On heating appliances not equipped with a draft hood, a barometric draft control **MUST** be installed to regulate proper air flow and fluctuations in the system's air flow during operation. Fluctuations can come from wind loads on the outlet of the venter, house depressurization during windy days, and the different house ventilation requirements between summer and winter operation. Use a Field Controls Type MG-1 Barometric Draft Control. Gas-Fired draft induced systems should have a single-acting or double-acting barometric draft control installed.



INSTALLATION OF POWER VENTER

CAUTION: Failure to install, maintain, and/or operate the power venting system in accordance with manufacturer's instructions will result in conditions which may produce bodily injury and/or property damage.

1. Remove power venter from box and inspect unit for damage. If the carton has been crushed or mutilated, check unit very carefully for damage. Rotate venter wheel to ensure that the motor and venter wheel rotate freely. **DO NOT** install if any damage is apparent. Refer to unit sizing chart to check proper venting sizing.
2. Location of the termination of the venting system should be installed in accordance with the National Fuel Gas Code, ANSI Z233.1, manufacturer's recommendations, and/or local codes which are applicable. See the following requirements or refer to Diagram A for typical locations.
 - A. The exit termination of mechanical draft systems shall not be less than 7' above grade when located adjacent to public walkways.
 - B. A venting system shall terminate at least 3' above any forced air inlet located within 10'.
 - C. The venting system of other than a direct vent appliance shall terminate at least 4' below, 4' horizontal from, or 1' above any door, window, or gravity air inlet into the building.
 - D. The vent termination of a direct vent appliance with an input of 50,000 BTU/HR or less, shall be located at least 9" from any opening through which vented gases could enter the building. With an input over 50,000 BTU/HR, a 12" termination clearance shall be required.
 - E. The vent termination point shall not be installed closer than 3' from an inside corner of an L-shaped structure.
 - F. The vent termination should not be mounted directly above or within 3' horizontally from an oil tank vent or gas meter.
 - G. The bottom of the vent terminal shall be located at least 12" above finished grade.

NOTE: If mounting the power venter through a combustible wall material, a minimum clearance of 1/2" must be maintained between the venter outer pipe and combustible materials.

SIDEWALL VENT HOOD INSTALLATION

1. Use the inside wall plate as a template to mark the hole location. Cut a 1" larger than the marked hole to facilitate easy installation (See Figure 4).
2. Center vent hood through the hole from outside. Fasten the vent hood to the outside wall within the appropriate type of mounting screws.
3. Fasten the wall end plate to the inside wall with the appropriate type of mounting screws. **NOTE:** Apply sealant to the outside mounting plate of the vent hood to prevent leakage.
4. Connect the venter outlet or a properly sized section of vent pipe onto the inner pipe of the vent hood. Fasten the connection with three sheet metal screws or equivalent fastening method.
5. Seal the vent hood inlet connection and any other vent pipe joints on the outlet side of the venter with an approved high temperature silicone adhesive sealant or equivalent material.




Figure 4



VENTER LOCATION

NOTE: DO NOT enclose the space between the plates on the outside of the vent hood or between the inner and outer pipe of the vent hood. This might cause overheating of the wall structure. Local codes might require fencing around the vent hood outlet.

Install the power venter onto the vent hood inlet or as close to the vent hood inlet as possible. Always install the venter such that the motor shaft is horizontal and the pressure switch diaphragm is vertical (See Figure 5).

When venting a draft induced gas-fired heating appliance a barometric draft control must be installed on the vent system between the appliance outlet and the venter inlet (See Figure 6).

CAUTION: The power venter should never be installed with the motor shaft in the vertical position. This could allow heat to be trapped in the venter housing and radiate through the motor possibly causing motor deterioration and premature failure. Never attach the venter inlet directly to the outlet of the heating appliance. Also, a minimum of 6" clearance between the venter housing and combustible materials must be maintained.




Figure 5




Figure 6

CONNECTING VENTER TO FLUE PIPE

NOTE: The power venter should be supported in accordance with National Fuel Gas Code Z223.1, Section 7.910 as follows: A vent connector shall be supported for the design and weight of the material employed to maintain clearances and to prevent physical damage and separation of joints.

NOTE: For gas-fired heating appliances not equipped with a draft hood, a barometric draft control must be installed between the heating appliance exhaust outlet and the power venter inlet to regulate any draft fluctuations during operation.

1. Use approved vent connectors to join the heating appliance outlet to the venter inlet securing each joint with sheet metal screws or equivalent means of fastening when required.
2. Seal all pipe joints on the outlet side of the venter with a high temperature silicone adhesive or equivalent. Test the vent connections for leaks by using a soap solution as recommended by the National Fuel Gas Code, ANSI Z223.1, Section 4.1.1.

**CONTROL
WIRING
SOLUTIONS**





OPTIONAL GSK-3 EXHAUST SPILLAGE DETECTOR SWITCH

NOTE: Installation of the GSK-3 secondary safety switch is recommended for LP and natural gas-fired appliances with a draft hood. This switch will detect exhaust gas spillage out of the draft hood due to a blocked vent system and/or inadequate draft during operation. When this switch senses spillage it interrupts the power supply to the gas valve which terminates the burner operation.

1. Mount the GSK-3 on the lower edge of the draft hood with the exposed thermal disk directed into the draft hood (See Figure 7).
2. Route the electrical wires along the heating appliance cabinet within an accepted wiring enclosure in accordance with the National Electrical Code and any applicable local codes. Keep the wires away from any HOT surfaces.
3. Wire the switch into the low voltage thermostat circuit. Refer to the appropriate wiring diagram in this manual.
4. After installation, check the amperage through the thermostat circuit and adjust the anticipator if necessary.




Figure 7

GENERAL WIRING INSTRUCTIONS


CAUTION: Disconnect electrical power before wiring power venter!

Connect line voltage (110/120 VAC) through junction box access hole labeled 120 VAC ONLY. Connect low voltage control wiring through junction box access hole labeled 24 VAC CONTROL WIRING ONLY. Power venter **MUST** be grounded.

Check ground circuit to make certain that the venter has been properly grounded. The wiring must be protected by an over current protection circuit such as a fuse or circuit breaker rated at 15 amperes. Prevent wiring contact with any heat source. Wire the venter in accordance with the National Electrical Code and applicable local codes. Refer to Diagram B for proper wiring specification.



GENERAL WIRING INSTRUCTIONS - CONTINUED



ADJUSTING THERMOSTAT ANTICIPATOR

If connecting the Power Venter system to a gas appliance with a thermostat anticipator, refer to the following to make adjustments.

1. Disconnect on side of the thermostat circuit at the gas valve or burner control, and connect an amperage meter into the circuit. With the system running, take an amperage reading on the circuit.
2. Check the nameplate or instructions for the thermostat to obtain the proper amperage level. Adjust amperage level by moving the anticipator lever.
3. Reconnect the thermostat to the gas valve and start the system operation.
4. Time the burn cycles and adjust as follows; To make the cycle time longer, increase the amount on the anticipator (Example: .45 to .5 Amps); to decrease cycle time, reduce the amount on the anticipator (Example: .45 to .3 Amps) (See Figure 4)




Figure 8



AIRFLOW ADJUSTMENTS

1. To properly adjust the venter air flow, loosen the inlet ring screws and open the choke plate approximately 1/2 to 3/4 open (See Figure 9). Start the heating appliance following the manufacturer specified procedure, and set the thermostat to call for heat.
2. After the system has operated for several minutes to stabilize the exhaust gas temperature, check for air flow at the draft hood or the heating appliance outlet using a velocity meter, draft meter, or match test procedure.
3. Adjust the venter chock plate inward and outward to obtain the minimum draft necessary to maintain venting. Then increase the draft slightly (approximately 10% over minimum flow rate) to ensure proper venting during any variations in venter performance, such as wind load or house depressurization.
4. Secure the choke plate into position by tightening the screws on the inlet collar (See Figure 9)




Figure 5

MULTIPLE VENTING SYSTEMS

1. To vent a 24 VAC controlled boiler or furnace and a 30 millivolt residential water heater using one PVG power venter, refer to the following.
 - A. Follow the instructions for safe and proper venting previously specified in this manual. Make sure that the combined gross BTU/HR input and equivalent vent pipe length does not exceed the maximum venting capacity of the venter selected.
 - B. A CK-20FV control kit **MUST** be added to the system to properly control the venter during operation of the water heater. Refer to Figure 10 and Diagrams C and D (page 13) for vent pipe arrangement and wiring information.
2. To vent two 24 VAC appliances using one PVG power venter refer to the following.





Figure 10

- A. Follow the instructions for safe and proper venting previously specified in this manual. Make sure that the combined gross BTU/HT input and equivalent vent pipe length does not exceed the maximum venting capacity of the venter selected.
- B. A CK-41F Control Kit must be added to the system to properly control the venter when common venting an additional 24 VAC furnace or boiler. Tee the draft tube on the PVG unit to connect to the air pressure switch on the Control Kit. Refer to Diagram D for wiring instructions.


PV SERIES POWER VENTER: VERTICAL VENTING OPTION

Diagram C illustrates correct and incorrect installation of PV series venter in vertical vent configuration (except PVE-1200). The correct installation maintains the required vertical position of the pressure switch; the incorrect installation does not. The following conditions must also be observed:

- Natural gas, LP gas or #2 fuel oil appliance rated 75% or greater non-condensing type of appliance
- Maximum input temperature at power venter: 575°F



PVG



----- New wire supplied by installer

* Input power and jumper wire connection must be to the same polarity or equipment damage may occur.

Set Voltage Selection Switch to 24V

Diagram D

PV SERIES POWER VENTER: VERTICAL VENTING OPTION - CONTINUED




Diagram E

GENERAL INSTALLATION INSPECTION

1. Visually inspect the venting system for proper size and determine that there is no blockage, restriction, leakage, or corrosion, or other deficiencies which could cause unsafe operation.
2. To the extent possible, close all building doors, windows, and all doors to the room in which the heating appliance is located. Turn on clothes dryer and any exhaust fans so that they operate at maximum speed. Do not operate a summer exhaust fan. Also, close all fireplace dampers. If after completing steps 3 through 7 it is believed that sufficient combustion air is not available, refer to the National Fuel Gas Code ANSI Z223.1 or any local codes for proper guidelines.
3. Place the appliance inspected into operation. Follow the lighting instructions and adjust the thermostat so that the heating appliance will operate continuously.
4. Determine that the burner is operating and that the main burner ignition functions satisfactorily, by interrupting the electrical power of the appliance in any safely convenient manner. Test the burner safety device to determine if it is operating properly by extinguishing the pilot or disconnecting the flame safety circuit.
5. Visually determine that the main burner is burning properly, i.e. no floating, lifting, or flashbacks. Adjust the primary air shutter as required by the appliance manufacturer. If the appliance is equipped with high and low flame control or flame modulation, check for proper main burner operation at both flame levels.
6. Test for exhaust gas spillage at the draft hood or the barometric draft control after approximately 5 minutes of main burner operation. Use a draft meter, flame, or smoke from match, candle or cigarette.
7. Turn on all fuel burning appliances within the same room so that they operate at their maximum capacity. Then repeat steps 5 and 6.
8. Return all doors, windows, exhaust fans, fireplace dampers, and any other fuel burning appliances to their previous condition.

SYSTEM CONTROL CHECK PROCEDURES

1. Adjust the thermostat to call for heat and observe the power venting system for proper operation sequence. Repeat as necessary.
 - A. Thermostat calls for heat.
 - B. Venter relay is energized which starts the motor.
 - C. Pressure switch closes which allows burner to fire.
 - D. Thermostat is satisfied, burner stops operation.
 - E. Venter continues to operate for up to 2 minutes during the post purge cycle.
2. While the system is in operation, disconnect the draft tube to the air pressure switch. The pressure switch should open and interrupt burner operation. Reconnect the draft tube to the air pressure switch which should allow the burner to relight.
3. If a GSK-3 secondary safety switch is installed, allow the vent pipe to cool and disconnect the vent pipe between the appliance outlet and venter inlet. Block the vent connected to the appliance with a non-combustible material. Activate the heating system main burner and verify that the GSK-3 shuts down the burner within a few minutes or less. Reset the GSK-3 and repeat.

MAINTENANCE

1. **Motor:** Inspect the motor once a year - motor should rotate freely. To prolong the life of the PVG-600 motor, it must be lubricated with six drops of SWG Superlube, Part # 46226200, annually. The PVG-100 and PVG-300 have sealed ball bearings, and therefore do not need to be oiled.
2. **Blower Wheel:** Inspect the blower wheel annually to clear any soot, ash, or coating which inhibits either rotation or air flow. Remove all foreign materials before operating.
3. **Vent System:** Inspect all vent connections annually for looseness, for evidence of corrosion, and for flue gas leakage. Replace, seal, or tighten pipe connections if necessary. Check the power venter choke plate to ensure it is secured in place. Check the barometric draft control, if installed, to ensure the gate swings freely.
4. **System Safety Device:** With the heating system operating, disconnect the pressure sensing tube from the pressure switch on the venter. This should stop the burner operation. Reconnecting the tube will relight the burner. For 30 millivolt operating systems, disconnect one lead of the spill switch circuit from the thermocouple junction block. This should shut off the pilot and the burner. Reconnect will all relighting of the pilot.

TROUBLESHOOTING

SYMPTOM	POSSIBLE REASON	CORRECTION
Burner does not fire when thermostat calls for heat	Draft tube is loose or blocked	Ensure draft tube is securely fastened to the air pressure switch and free of obstructions
	No continuity across pressure switch terminals	Check for continuity across pressure switch terminals when venter is operating
	Faulty wiring between air pressure switch and appliance	Check the power between T2 and T3 for 24 VAC, if you have 24 VAC inspect and correct wiring connections between air pressure switch and appliance. If no power, replace pressure switch
Venter does not activate when thermostat calls for heat	Relay not closing	Check power between T1 and T2 for 24 VAC to see if relay closes when thermostat calls for heat. If you have good power use a jumper from L1 to M to see if the motor runs. If the motor does not run replace the motor, if not replace the relay.
	Loose or faulty wiring connections	Inspect and secure wiring connections.
	Motor shaft obstructed	Check motor for unrestricted shaft rotation
Exhaust gas odor	Improper draft level	Check system draft level during operation
	Leakage in vent system on outlet side of venter	Inspect vent system for leakage and repair as needed
	Negative pressure in building	Check for negative pressure and correct building ventilation as required

This manual may be downloaded and printed from the Field Controls website (www.fieldcontrols.com)

WARRANTY

For warranty information about this or any Field Controls product, visit:
www.fieldcontrols.com/ventCool

Field Controls Technical Support
1.800.742.8368
fieldtec@fieldcontrols.com



FIELDCONTROLS

Phone: 252.522.3031 • Fax: 252.522.0214
www.fieldcontrols.com